

Certificate

Registration No.: PV 60021733

Page 1

Report No.: 21207417-2

License Holder:

SunPower Corporation
3939 North First Street
San Jose, CA 95134
USA

Product:

PV Modules

Type:

SPR-yyyE-WHT-I; SPR-yyyE-BLK-I;
SPR-yyyE-WHT-D; SPR-yyyE-BLK-D;

yyy stands for: 335,333,330,327,325,323,320, 318,315,313,310,
308,305,303,300,298,295,293,290,285,280.

Using C65 125mmx125mm pseudo-square cells

SPR-yyy-WHT-I; SPR-yyy-BLK-I;

SPR-yyy-WHT-D; SPR-yyy-BLK-D;

yyy stands for: 325,323,320, 318,315,313,310,308,305,303,300,
298,295,293,290,285,280.

Using C50 125mmx125mm pseudo-square cells

WHT: white back sheet; BLK: black back sheet

Manufacturing Plant:

SunPower Philippines Mfg. Ltd.
Lot 1 Blk3 East Main Ave. Ext.

Laguna Technopark – SEZ, Phase V
Barangay Loma, Biñan, Laguna, 4027
Philippines

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21208932.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 12 October 2012.



Dipl.-Ing. M. Adrian

Cologne, 9 June 2008